

DRIFTSRAPPORT

Månedssrapport Juni 2024

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	2564,84 m ³
Boring 1	1274,43 m ³
Boring 2	1290,41 m ³
TOTAL UDPUMPET	2544,56 m ³
Udpumpning	2544,56 m ³
TOTAL SKYLLEVAND	7,38 m ³
Skyllevand	7,38 m ³

ELFORBRUG




ELFORBRUG	
Samlet proces	2506 kWh
Delproces / udpumpning	882 kWh



NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



FILTRE

Filter 1	6 skyl
Filter 2	6 skyl
Filter 3	9 skyl
Filter 4	9 skyl

DRIFTTIMER



BORINGER	
1	171 timer
2	172 timer
PUMPER	
1	360 timer
2	360 timer
FILTERMOTOR	
1	343 timer
2	1 timer



Blue Control®
BC7000

DRIFTSRAPPORT

Månedssrapport Juni 2024

Faurbo Vandværk


2/2



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-48,70 m	-52,60 m	3,90 m	1274,43 m ³
2	-48,68 m	-52,73 m	4,05 m	1290,41 m ³

Fordeling for indvundet vand



Blue Control®
BC7000