

# DRIFTSRAPPORT

Månedsrapport November 2024

Faurbo Vandværk

1/2



## MÆNGDER

TOTAL INDVUNDET	1993,97 m <sup>3</sup>
Boring 1	996,58 m <sup>3</sup>
Boring 2	997,39 m <sup>3</sup>
TOTAL UDPUMPET	1976,27 m <sup>3</sup>
Udpumpning	1976,27 m <sup>3</sup>
TOTAL SKYLLEVAND	4,52 m <sup>3</sup>
Skyllevand	4,52 m <sup>3</sup>

## ELFORBRUG




ELFORBRUG	
Samlet proces	2316 kWh
Delproces / udpumpning	783 kWh



## NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



## FILTRE

Filter 1	4 skyl
Filter 2	4 skyl
Filter 3	7 skyl
Filter 4	7 skyl

## DRIFTTIMER



BORINGER	
1	146 timer
2	145 timer
PUMPER	
1	360 timer
2	360 timer
FILTERMOTOR	
1	291 timer
2	1 timer



Blue Control®  
BC7000

# DRIFTSRAPPORT

Månedssrapport November 2024

Faurbo Vandværk


2/2



## NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-48,75 m	-52,49 m	3,74 m	996,58 m <sup>3</sup>
2	-48,73 m	-52,69 m	3,96 m	997,39 m <sup>3</sup>

Fordeling for indvundet vand



Blue Control®  
BC7000