

DRIFTSRAPPORT

Månedsrapport September 2024

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	2119,72 m ³
Boring 1	1060,55 m ³
Boring 2	1059,17 m ³
TOTAL UDPUMPET	2100,86 m ³
Udpumpning	2100,86 m ³
TOTAL SKYLLEVAND	5,99 m ³
Skyllevand	5,99 m ³

ELFORBRUG




ELFORBRUG	
Samlet proces	2308 kWh
Delproces / udpumpning	800 kWh



NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



FILTRE

Filter 1	5 skyl
Filter 2	5 skyl
Filter 3	8 skyl
Filter 4	8 skyl

DRIFTTIMER



BORINGER	
1	149 timer
2	147 timer
PUMPER	
1	360 timer
2	360 timer
FILTERMOTOR	
1	296 timer
2	1 timer



Blue Control®
BC7000

DRIFTSRAPPORT

Månedsrapport September 2024

Faurbo Vandværk


2/2



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-48,80 m	-52,71 m	3,91 m	1060,55 m ³
2	-48,69 m	-53,11 m	4,42 m	1059,17 m ³

Fordeling for indvundet vand



Blue Control®
BC7000