

DRIFTSRAPPORT

Månedsrapport Juli 2024

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	2230,64 m ³
Boring 1	1121,18 m ³
Boring 2	1109,46 m ³
TOTAL UDPUMPET	2214,68 m ³
Udpumpning	2214,68 m ³
TOTAL SKYLLEVAND	6,18 m ³
Skyllevand	6,18 m ³

ELFORBRUG




ELFORBRUG	
Samlet proces	2317 kWh
Delproces / udpumpning	833 kWh



NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



FILTRE

Filter 1	5 skyl
Filter 2	5 skyl
Filter 3	8 skyl
Filter 4	8 skyl

DRIFTTIMER



BORINGER	
1	152 timer
2	150 timer
PUMPER	
1	380 timer
2	364 timer
FILTERMOTOR	
1	302 timer
2	1 timer



Blue Control®
BC7000

DRIFTSRAPPORT

Månedsrapport Juli 2024

Faurbo Vandværk


2/2



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-48,73 m	-52,64 m	3,91 m	1121,18 m ³
2	-48,72 m	-52,74 m	4,02 m	1109,46 m ³

Fordeling for indvundet vand



● Boring 1 : 50.3%
● Boring 2 : 49.7%



Blue Control®
BC7000