

DRIFTSRAPPORT

Månedssrapport August 2024

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	2484,37 m ³
Boring 1	1241,37 m ³
Boring 2	1243,00 m ³
TOTAL UDPUMPET	2465,31 m ³
Udpumpning	2465,31 m ³
TOTAL SKYLLEVAND	6,06 m ³
Skyllevand	6,06 m ³

ELFORBRUG




ELFORBRUG	
Samlet proces	2579 kWh
Delproces / udpumpning	877 kWh



NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



FILTRE

Filter 1	5 skyl
Filter 2	5 skyl
Filter 3	8 skyl
Filter 4	8 skyl

DRIFTTIMER



BORINGER	
1	172 timer
2	171 timer
PUMPER	
1	364 timer
2	380 timer
FILTERMOTOR	
1	342 timer
2	1 timer



Blue Control®
BC7000

DRIFTSRAPPORT

Månedssrapport August 2024

Faurbo Vandværk


2/2



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-48,82 m	-52,64 m	3,81 m	1241,37 m ³
2	-48,81 m	-52,86 m	4,05 m	1243,00 m ³

Fordeling for indvundet vand



Blue Control®
BC7000