

# DRIFTSRAPPORT

Årsrapport 2024

Faurbo Vandværk

1/2



## MÆNGDER

TOTAL INDVUNDET	26987,82 m <sup>3</sup>
Boring 1	13538,00 m <sup>3</sup>
Boring 2	13449,82 m <sup>3</sup>
TOTAL UDPUMPET	26766,48 m <sup>3</sup>
Udpumpning	26766,48 m <sup>3</sup>
TOTAL SKYLLEVAND	64,49 m <sup>3</sup>
Skyllevand	64,49 m <sup>3</sup>

## ELFORBRUG




ELFORBRUG	
Samlet proces	29125 kWh
Delproces / udpumpning	10034 kWh



## NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



## FILTRE

Filter 1	63 skyl
Filter 2	63 skyl
Filter 3	94 skyl
Filter 4	94 skyl

## DRIFTTIMER



BORINGER	
1	1891 timer
2	1868 timer
PUMPER	
1	4389 timer
2	4395 timer
FILTERMOTOR	
1	3756 timer
2	8 timer



Blue Control®  
BC7000



## NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-48,13 m	-52,87 m	4,74 m	13538,00 m <sup>3</sup>
2	-48,46 m	-53,11 m	4,65 m	13449,82 m <sup>3</sup>

Fordeling for indvundet vand

