

DRIFTSRAPPORT

Månedsrapport December 2024

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	2023,27 m ³
Boring 1	1013,42 m ³
Boring 2	1009,85 m ³
TOTAL UDPUMPET	2000,40 m ³
Udpumpning	2000,40 m ³
TOTAL SKYLLEVAND	5,48 m ³
Skyllevand	5,48 m ³

ELFORBRUG




ELFORBRUG	
Samlet proces	2341 kWh
Delproces / udpumpning	804 kWh



NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



FILTRE

Filter 1	5 skyl
Filter 2	5 skyl
Filter 3	7 skyl
Filter 4	7 skyl

DRIFTTIMER



BORINGER	
1	152 timer
2	150 timer
PUMPER	
1	364 timer
2	380 timer
FILTERMOTOR	
1	302 timer
2	1 timer



Blue Control®
BC7000

DRIFTSRAPPORT

Månedssrapport December 2024

Faurbo Vandværk


2/2



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-48,70 m	-52,41 m	3,71 m	1013,42 m ³
2	-48,74 m	-52,57 m	3,83 m	1009,85 m ³

Fordeling for indvundet vand



Blue Control®
BC7000