

# DRIFTSRAPPORT

Månedsrapport Oktober 2024

Faurbo Vandværk

1/2



## MÆNGDER

TOTAL INDVUNDET	2131,26 m <sup>3</sup>
Boring 1	1064,31 m <sup>3</sup>
Boring 2	1066,95 m <sup>3</sup>
TOTAL UDPUMPET	2104,81 m <sup>3</sup>
Udpumpning	2104,81 m <sup>3</sup>
TOTAL SKYLLEVAND	6,99 m <sup>3</sup>
Skyllevand	6,99 m <sup>3</sup>

## ELFORBRUG




ELFORBRUG	
Samlet proces	2288 kWh
Delproces / udpumpning	820 kWh



## NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



## FILTRE

Filter 1	6 skyl
Filter 2	6 skyl
Filter 3	7 skyl
Filter 4	7 skyl

## DRIFTTIMER



BORINGER	
1	150 timer
2	149 timer
PUMPER	
1	380 timer
2	365 timer
FILTERMOTOR	
1	299 timer
2	1 timer



Blue Control®  
BC7000

# DRIFTSRAPPORT

Månedsrapport Oktober 2024

Faurbo Vandværk


2/2



## NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-48,79 m	-52,77 m	3,98 m	1064,31 m <sup>3</sup>
2	-49,01 m	-53,07 m	4,06 m	1066,95 m <sup>3</sup>

Fordeling for indvundet vand



Blue Control®  
BC7000